

Our ref: DM# 13507648

14 December 2015

Elizabeth Walters
Assistant Director Electricity
Economic Regulation Authority
Level 4, 469 Wellington Street
PERTH WA 6000

Dear Elizabeth

November 2015 Technical Rules Amendment Submission – Addendum

I refer to the Western Power request for a number of amendments to the 2011 Technical Rules submitted to the Authority on 6 November 2015. After further review of the document, Western Power requests the following change to clarify the wording for the new DC injection clause 3.2.1(g)(2) being sought. This change occurs on page 10 of the amendment document.

Modified wording for the new clause 3.2.1(g)(2), with changes highlighted:


(2) A User connecting at *low voltage* must not inject into the *distribution system* any DC component of current produced by its own equipment that exceeds ~~either 5 mA, or~~ the maximum value calculated from 0.5% of the rated service capacity, per phase, of the *connection point*, or 5 mA, whichever is greater.

Modified wording for the new clause 3.2.1(g)(2):

(2) A User connecting at *low voltage* must not inject into the *distribution system* any DC component of current produced by its own equipment that exceeds the maximum value calculated from 0.5% of the rated service capacity, per phase, of the *connection point*, or 5 mA, whichever is greater.

If you have any queries with regards to this request, please do not hesitate to contact Lindsay Offer on (08) 9326 6303.

Yours sincerely,



Margaret Pырchla
Regulatory Compliance Manager