

ELECTRICITY INDUSTRY ACT 2004
ELECTRICITY INDUSTRY (WHOLESALE ELECTRICITY - MARKET)
REGULATIONS 2004
Wholesale Electricity Market Rules

IMO AMENDING RULES RC_2009_09 MADE ON 17 March 2009

These Amending Rules commence at 08.00am on 18 March 2009

The following clauses are amended (~~deleted wording~~, new wording):

7.10.5. Subject to clause 7.10.5A, ~~Where~~ System Management considers that a Market Participant has not complied with clause 7.10.1 in relation to any of its Registered Facilities in a manner that:

- (a) threatens Power System Security or Power System Reliability;
- (b) would require System Management to issue instructions to the Registered Facilities of the Electricity Generation Corporation or Registered Facilities covered by any Balancing Support Contract or Ancillary Service Contract; or
- (c) would require System Management to issue Dispatch Instructions to other Registered Facilities in accordance with clauses 7.6.3 or 7.6.4;

System Management must warn the Market Participant about the deviation and request an explanation for the deviation; and cessation of the behaviour within a time that System Management considers reasonable.

7.10.5A System Management is not required to follow the process in clause 7.10.5 where:

- (a) it considers that a failure to comply with clause 7.10.1 does not threaten Power System Security or Power System Reliability;
- (b) the Market Participant has notified System Management in advance that it expects to deviate from its Resource Plan in order to subject the relevant Facility to testing, to enable it to enter full commercial operation for the first time;
- (c) the Market Participant has provided System Management with a testing plan;
- (d) System Management has notified the Market Participant that it approves the plan; and
- (e) the deviation is in System Management's opinion consistent with the activities detailed in the approved testing plan.