

Economic Regulation Authority  
 Level 4, Albert Facey House  
 469 Wellington Street  
 Perth WA 6000

Attention: Elizabeth Walters

3<sup>rd</sup> June 2016

Dear Ms Elizabeth Walters,

**Proposed Amendments to Western Power’s Technical Rules Submitted April 2016**

It seems that the proposed change to Clause 2.5.4 may not actually result in improved efficiency of investment. In this submission I present some calculations which show possible outcomes.

Of course, the capacity of a substation increases with the addition of more transformers. I provide calculations in Table 1 that show precisely how much the capacity of a given substation increases and how it differs depending on the definition of NCR (Normal Cyclic Rating) in its current form and the proposed amended form.

For simplicity, I make the assumption that each transformer (including the RRST, Rapid Response Spare Transformer) has a capacity of 33 MVA. I have included N-1 substation capacity for illustration and as a sanity check because, as I understand it, the NCR capacity should always be similar to but slightly higher than the N-1 capacity.

Table 1 – Comparison of the three criteria shows that the proposed change leads to reduced substation capacity.

	Number of Transformers	1	2	3	4	5
	Sum capacity	33.0	66.0	99.0	132.0	165.0
Assumption	Capacity of each transformer (including RRST) for simplicity of calculations	33.0	33.0	33.0	33.0	33.0
N-1 now	N-1 substation capacity	10.0	33.0	66.0	99.0	132.0
NCR now	Permissible loss of load = min ( 33 * 75%, RRST * 90% ) = 33 * 75%	24.8	24.8	24.8	24.8	24.8
	Capacity = N-1 capacity + permissible loss	24.8	57.8	90.8	123.8	156.8
NCR proposed	Maximum power transfer is 75% of the power transfer capacity, which is the sum capacity	24.8	49.5	74.3	99.0	123.8

Note: the “N-1” case is only illustrative, the cases to be compared are “NCR now” and “NCR proposed”.

Note: all values are MVA (Mega-Volt-Amperes).

Let me offer an explanation of my understanding that may clarify the way in which I have made the calculations in Table 1. Suppose that a substation comprised of homogenous transformers rated at 33 MVA were required to satisfy the N-1 criterion. The maximum capacity for a station with two transformers would be 33 MVA, the capacity of a single transformer. The maximum capacity for a station with three transformers would be 66 MVA, the capacity of two transformers, and so on.

The N-1 criterion is conservative, because it requires having what is essentially a spare transformer in each zone substation. The NCR risk criterion is less conservative, because it allows a population of zone substations of, say fifty North of the river, to share a single spare transformer (RRST). This is an enormous economic saving, given that each transformer costs say \$10 million, whereas making a substation NCR requires a construction effort that is only a fraction of the cost.

According to Table 1, a substation of three transformers will have a capacity of 90.8 MVA under the current NCR definition but a capacity of only 74.3 MVA under the proposed redefinition of NCR. For a substation of four transformers, the capacities are 123.8 MVA and 99.0 MVA respectively which is a huge discrepancy.

A good definition of NCR is one which maximizes the capacity of substations in order to defer investment as long as possible. I hope that the calculations I have presented can prompt more analysis of the quantitative aspects of the proposed amendment.

Yours Sincerely,

A solid black rectangular box used to redact the signature of James Davidson.

James Davidson